Luminaire	Luminaire Type/Ref:			Date of	Date of Installation:	on:		Lo	Location:		
		1st year	ear	2nd Year	/ear	3rd Year	'ear	4th Year	éar	5th year	'ear
Month	Test	Sign	Date	Sign	Date	Sign	Date	Sign	Date	Sign	Date
_1	Functional										
2	Functional										
З	Functional										
4	Functional										
5	Functional										
6	1 hour										
7	Functional										
8	Functional										
9	Functional										
10	Functional										
11	Functional										
13	1 Hour										
•	3 Hour										

Unit 7 | Target Park | Shawbank Road | Lakeside | Redditch | B98 8YN | United Kingdom T: +44 (0)1527 51 51 50 F: +44 (0)1527 51 51 43 E: sales@espuk.com

 (\mathbf{b})

ation:

esp www.espuk.com

EM9W NM TWIN SPOT2

EMERGENCY LIGHTING LUMINAIRE INSTRUCTIONS AND TEST PROCEDURES

PARAMETER

Model no: EM9W NM & M TWIN SPOT2. Name of goods: LED Emergency Twin Spot Light.

TECHNOLOGY PARAMETER: Rated input supply: AC 240V 50Hz Rated output power: 2*15PCS LED Operating Environmental: Temperature:- 10-40°C Operating relative humidity: Less than 90% **Battery specification: 9.6V 2.2Ah Ni-Cd** Emergency Duration: More than 3 Hours. Change over time: Less than 1 second.

MONITORING

Green indicator lamp (LED) normally continuously 'on'. Indicator lamp goes out if A.C. supply or charger fails.

BATTERY

Ni-Cd rechargeable batteries.

TEMPERATURE Performance figures measured at 25 degrees C. ۲