



0843-CPR-0213 14 (UL)  
2531-CPR-CSP11212 20 (DBI)

## 27.6 Vdc Switch Mode Power Supply for Fire - EN54-4:1997 +A1+ +A2

### FEATURES

The powersupplies are an EN54-4:1997+A1+A2 approved power supply for use in Fire & Smoke and ventilation control Systems. Its regulated 27.6V dc output will supply up to 1.2 Amps continuous current into the load, in addition to providing up to 300mA for charging the standby battery capacities of 7Ah (BAT7). The power supply output features electronic short circuit protection under both mains and standby battery operation. Maximum battery life is assured through continuous active battery monitoring and the use of a two stage charger, comprising bulk and temperature compensated final float phase depending upon battery condition. Once fully charged the product operates in Eco power saving mode, whereby the batteries are charged for 4 hours in every 24 hour period while still being continuously monitored. This reduces wasted energy in charging already fully charged batteries and extends their working life. Deep discharge protection prevents premature battery failure when operating from standby for extended periods. Two sets of volt free solid state relay fault output signal (i) loss of mains and (ii) battery fault, charger fault and loss of output. In addition there is an optional plug in serial interface that can provide diagnostic and fault reporting information to supervisory systems.

- Certified by UL to EN54-4:1997 +A1 +A2.
- Up to 1.2A current to load at 27.6V dc nominal regulated output.
- Charging capability to support 7Ah Batteries
- Electronic overload protection shuts down output until overload or short circuit is removed.
- Battery Monitor detects battery missing, low battery, short-circuit or reverse connection or circuit impedance (Ri) in excess of 500m $\Omega$ , caused by connector or wiring problem/corrosion, within 4 hours.
- Battery charging circuit is energised only when a battery is correctly connected and the battery voltage is greater than 14 V.
- No loss of output during automatic connection of battery to load on loss of mains.
- Deep discharge protection disconnects battery from load when battery voltage falls below 21 V.
- Diagnostic indicator LED (Orange) (Internal).
- Fault indicator LED (Yellow) flashes on detection of output fault, battery fault, charger fault and mains failure.
- Mains indicator LED (Green) showing mains present Indicators check at start-up.
- Optional RS232 serial interface for fault reporting and diagnostics.

## SPECIFICATION

### Mains Input

|  |                                    |
|--|------------------------------------|
| Rated Voltage<br>(Operational voltage) | 110 – 240 V ac<br>(90 – 264 V ac)  |
| Frequency                              | 50 – Hz                            |
| Input current                          | < 1.0 Amps at full load            |
| Inrush current                         | 5A Max at 25 °C 110 V ac for 10 ms |
| Fuse                                   | T1.6 A 20mm, 250 V ac HRC          |

### Output

|  |   |
|--|---|
| <b>Voltage at full load</b><br>Mains power<br>Battery standby                      | 27.0 – 28.3V dc (range) (27.6V nominal)<br>20.3 – 26.0V dc  |
| <b>Ripple</b>  | <100 mV pk – pk max @ Rated Voltage   |
| <b>Fuse</b><br>Load<br>Battery   | F1.6 A<br>F1.6 A  |
| <b>Battery mode selected</b>   |   |
| <b>Continuous Output Current</b><br>No charging (Imax B)<br>With charging (Imax A) | 1.5 A<br>1.2 A  |
| <b>Battery Capacity</b>  | 2 x 7 Ah 12 V   |
| <b>Battery Charging</b>  | Constant current bulk charging to 80% capacity within 24 hours<br>Float charging to 100% within 48 hours<br>Eco charging and check every 24 hours<br>– (for up to 4 hours charge, level dependent on temperature) |
| Constant current charge  | 0.3 A   |
| Low battery threshold voltage  | 23 V  |
| Deep discharge protection  | Threshold voltage – 21 V  |
| Quiescent current – no load  | < 30 mA @ 27.6 V  |
| Quiescent current – batt cut off   | < 1 mA @ 27.6 V   |

### Mechanical

|   |                                  |
|---|----------------------------------|
| <b>Enclosure Dimensions</b><br>w x h x d (mm) | 300 x 240 x 60                   |
| <b>Weight (kg)</b> excluding battery          | 3.3 Kg                           |
| <b>Material</b>                               | 1.2 mm steel white powder coated |

### Environmental

|                         |  |
|-------------------------|--|
| Temperature – Operating | -10 to +40°C (operating) 75% RH non-condensing |
| Temperature - Storage   | -20 to +80°C (storage)                         |

**Connections and Signalling outputs**

|   |  |
|---|--|
| Load Output +/-                         | Screw terminals Voltage output to load   |
| GEN PSU Fault (normally closed contact) | 0.10 A @ 60V dc 16Ω solid state relay contacts, volt free<br>Open if Mains failed and battery voltage < 23 volts or fault PSU fault condition, (see below) |
| EPS Fault (normally closed contact)     | 0.10 A @ 60V dc 16Ω solid state relay contacts, volt free<br>Open if loss of mains for > 10 seconds  |
| Temperature sensor                      | Thermistor input from supplied battery terminal thermistor.  |
| BATT + / -                              | Connection to back up battery using supplied battery lead  |
| Optional Serial interface               | 5 pin header (For details contact Elmdene Technical Support)   |

**SIGNALLING AND DIAGNOSTICS****Fault Outputs**

| EPS Fault | GEN Fault | Condition        | Possible Cause                                     | Action  |
|-----------|-----------|------------------|--|---|
| CLOSED    | CLOSED    | Normal operation | Mains present<br>Battery healthy                   | None  |
| OPEN      | CLOSED    | Standby Mode     | Mains lost<br>Battery driving load                 | Investigate loss of mains   |
| CLOSED    | OPEN      | Fault Present    | Blown fuses<br>Battery fault<br><br>Internal fault | Investigate fault source using diagnostic LED<br>Rectify fault where possible |
| OPEN      | OPEN      | PSU Shutdown     | Mains lost<br>Standby battery exhausted            | Restore mains as soon as possible   |

**LED Indication**

| LED type   | Function   |
|------------|--|
| Yellow LED | Fault Indicator (See 'Fault Diagnostic table' User and Engineer) |
| Green LED  | Mains supply On Indicator  |
| Orange LED | Diagnostic Indicator (Not visible through front panel)           |

**Fault Diagnostic table – Front panel - User**

| Yellow LED Fault    | Green LED Mains | Condition        | Possible Cause                                 | Action                    |
|---------------------|-----------------|------------------|--|---------------------------|
| OFF                 | ON              | Normal operation | Mains present<br>Battery healthy               | None                      |
| FLASH<br>CONTINUOUS | ON or OFF       | Fault            | Blown fuses<br>Battery fault<br>Internal fault | Contact service engineer  |
| 1 PULSE/S           | OFF             | Standby Mode     | Mains lost<br>Battery driving load             | Investigate loss of mains |

**Fault Diagnostic table – Internal - Engineer**

| Orange LED Diagnostic | Green LED Mains | Condition                       | Possible Cause  | Action  |
|-----------------------|-----------------|---------------------------------|---|---|
| OFF                   | ON              | Normal operation                | Mains present<br>Battery fully charged  | None  |
|                       | OFF             | Standby Operation               | Mains Lost. No faults present<br>Battery driving load                           | Investigate loss of mains   |
| FLASH<br>CONTINUOUS   | ON or OFF       | No output                       | Output fuse blown<br>Output overload<br>Output short circuit                    | Check and replace output fuse<br>Disconnect output load and test load                                 |
| 1 PULSE               | ON              | Battery Charging                | No faults active<br>Battery charging normally but < 90% of full charge          | None  |
| 2 PULSES              | ON              | No Battery                      | Battery disconnected<br>Battery fuse blown<br>Battery heavily discharged        | Check battery connections<br>Check battery fuse<br>Check battery condition<br>Replace battery if aged |
|                       | OFF             | Low Battery Volts               | Standby Mode<br>Battery almost discharged                                       | Restore mains   |
| 3 PULSES              | ON or OFF       | Battery Fault                   | High impedance in battery connection<br>Battery internal fault                  | Check battery connections for corrosion. Replace battery if aged                                      |
| 4 PULSES              | ON or OFF       | Charger Fault                   | Internal failure of battery charger   | Return to manufacturer  |
| 5 PULSES              | ON or OFF       | Battery Temperature Probe Fault | Battery temperature monitor disconnected or damaged<br>PSU running in Safe Mode | Check temperature sensor connections and condition of sensor.<br>Replace if suspect                   |

## INSTALLATION

This Power Supply Unit (PSU) is only suitable for installation as permanently connected equipment (Power Supply Equipment / PSE). The PSE is NOT SUITABLE for external installation. This product is designed for the use in automatic fire detection and fire alarm systems. If the PSE is used as a power supply for Control and Indicating Equipment (CIE), the PSE shall be installed no further than 10cm from the CIE, and close coupled by conduit. This unit must be fed from a mains power source having a separate (approved) disconnect device and fitted with a fuse or other over-current protection device rated at 5 A maximum. Ensure that the disconnect device used has appropriate earth fault protection to the applicable standard.

Where the PSE is used to provide power to a fire alarm circuit, the mains isolation and disconnect device should be provided solely for this purpose and be suitably marked “FIRE ALARM – DO NOT TURN OFF”. All cabling should meet national and local fire system installation regulations, e.g. FP200 type cable for high integrity installations.

Where the PSE is used for other applications, it should be installed according to all relevant safety regulations applicable to that application.

Where the GEN PSU Fault and EPS Fault outputs are used, they should only be connected to circuits having voltages less than 60 Vdc.

### Cable Sizing

- 1) Mains input cable must be to the applicable standard with a 5 A or greater current capacity, i.e. 0.75 mm<sup>2</sup> nominal conductor area, having a minimum operating voltage of 300/500V ac.
- 2) The low voltage output cable must be sized to carry the rated load current to the devices connected to the PSE.
- 3) Mains input and low voltage output cables should be routed to use different entry / exit holes in the case. Bushes should be used to protect cable sheaths from chafing. Ensure that these bushes are correctly sized (i.e. close fitting with respect to cable sizing). Note that the bushes should meet a minimum flammability specification of UL94 HB.
- 4) All cabling should be securely fastened in position using a cable tie through the saddles provided.

### Mounting – 7Ah

- 5) The PSU is designed to support two 7Ah batteries and as such weighs a total of 8 Kg when loaded. Ensure that wall fixings are appropriate to support this weight.





Figure 2 – Battery location



**WARNING: ALWAYS FIT 2 BATTERIES and wire in series, the product will not work with a single 12V battery**

## COMMISSIONING


### Mains Power Up

- 1) With no external connections made to the PSE, connect the mains input wires to the terminal block, **ensuring that the mains isolator (disconnect device) is open**. Fasten wiring in place with cable tie to saddle. **Note: Equipment must be earthed.**
- 2) Apply mains input. Confirm that all LED indicators flash on briefly proving integrity of indicating circuits. Ensure that the green Mains LED then stays illuminated and that the yellow Fault LED flashes after approximately 3 s (indicating a disconnected battery).
- 3) Disconnect the mains power.

### Load Output and Remote Signalling


- 4) Connect the EPS and PSU Fault outputs to the appropriate inputs of control equipment if remote fault monitoring is required.
- 5) Connect the load (output) wiring as shown in Figure. 3. Cable tie to saddle provided (adjacent to exit hole).

Figure 3 – Connections



- 6) Re-apply mains. Verify that the green Mains LED illuminates and the yellow Fault LED flashes after approximately 3 s (disconnected battery).
- 7) If connected, verify that the EPS Fault monitor shows a *closed* contact and the GEN PSU Fault monitor shows an *open* contact.
- 8) Perform a full functional test of connected system (load) including full alarm condition.

Figure 4 – Terminal labels



### Standby Battery

- 9) Mount the appropriate batteries as shown in Figure 2. Where a dual box solution is used all cabling between the two boxes should be routed to use separate case entry/exit holes from other cabling and use suitable bushes to protect the cables.
- 10) With mains *disconnected*, connect the two 12 V standby batteries in series using the single cable provided. Connect the *negative* of one battery to the *positive* of the other. See Figure 3.  
***CAUTION – DO NOT CONNECT the two remaining (free) battery terminals to each other!***
- 11) Connect the PCB terminals Batt+ and Batt– to the free Positive and Negative terminals of the batteries using the cables provided. See Figure 2 and 3. ***With the cable pair ALREADY screwed into the battery terminals the FINAL connection MUST be to the battery itself.***
- 12) ***CAUTION – significant energy can be released from an SLA battery. When connecting the last battery lead, take extreme care to attach the cable ONLY to the correct terminal. Avoid shorting it to any other terminal or conducting surface.***
- 13) Connect the battery temperature sensor (two white wires) to the PCB terminals Temp Sense. See Figure 4. Wires can be connected either way around.
- 14) Verify that the yellow Fault LED does not flash (battery connection detected). Verify that the remote PSU Fault monitor shows a *closed* contact.
- 15) Disconnect the mains power. Verify that the green Mains LED extinguishes and the Yellow Fault LED starts to pulse (indicating that the PSE is running from its standby batteries).
- 16) If connected, verify that the EPS Fault monitor shows an *open* contact and the GEN PSU Fault monitor shows a *closed* contact.
- 17) Verify that the standby batteries are now driving (supporting) the system load. Perform a full functional test of system including full alarm condition Note: ensure batteries have sufficient charge to support the system under full load.

### Final

- 18) Reconnect the mains. Verify that the green Mains LED illuminates and the yellow Fault LED extinguishes.
- 19) If connected, verify that the EPS Fault monitor shows a *closed* contact and the GEN PSU Fault monitor shows a *closed* contact.
- 20) Disconnect one of the battery leads, ensuring that no exposed section of conductor or connector is allowed to contact exposed metal-work, other PSE terminals, or other battery terminals.
- 21) Verify that, in less than 1 minute, the yellow Fault LED starts to flash, and that the orange Diagnostic LED flashes in a 2 pulse repeating pattern, (indicating that battery disconnection was detected).
- 22) Reconnect the battery lead and, after approximately 3 s, verify that that the Fault LED does not flash. (Audible click can be heard as the battery relay closes, then a second click while the charger is tested.)
- 23) ***Note: If it is necessary to obtain confirmation of charging current; between steps 18 and 20, an ammeter can be placed in series with the battery leads. Continue to observe caution with all exposed conductors when inserting or removing the meter and when restoring normal battery wiring.***

## OPERATING INSTRUCTIONS

In the event of loss of mains, a battery fault or a GEN PSU fault, the corresponding Fault signal contacts will open.

If the output of the PSE fails, the cause of the failure should be investigated e.g. short circuit load, connection of a deeply discharged battery. The fault should be rectified before restoring power to the PSE. If any of the fuses require replacing, ensure the correct fuse rating and type is used.

## MAINTENANCE

This unit is intended for use by Service Personnel only. There are NO USER SERVICEABLE parts inside. There is no regular maintenance required of the PSE other than periodic testing, and replacement of the standby battery. ***Reference should be made to the battery manufacturer's documentation to determine typical/expected battery life with a view to periodic replacement of the battery.***

## COMPLIANCE

This power supply unit meets the essential requirements of the following EU Directives:

CPR: 305/2011 EU

EMC: 2014/30/EU

Low Voltage: 2014/35/EU

WEEE: 2012/19/EU

RoHS2: 2011/65/EU

Functional standard: EN54-4:1997 +A1 +A2  
Environmental Class II

Certification Body: Underwriters Laboratory

Declaration of Performance: DOP2014/02  
DOP2014/03



0843-CPR-0213 14 (UL)  
2531-CPR-CSP11212 20 (DBI)

EN54-4:1997 +A1 +A2  
Power Supplies intended for use  
in fire detection and fire alarm  
systems

## DISPOSAL OF PRODUCT AT END OF LIFE

This product falls within the scope of EU Directives 2012/19/EU Waste Electrical and Electronic Equipment (WEEE) and 2013/56/EU (Battery). At the end of life, the product must be separated from the domestic waste stream and disposed via an appropriate approved WEEE disposal route in accordance with all national and local regulations.

Before disposal of the product, any batteries must be removed, and disposed separately via an appropriate approved battery disposal route in accordance with all national and local regulations. Package used batteries safely for onward transport to your supplier, collection point or disposal facility.

**Caution: Risk of fire or explosion if bare battery wires are allowed to touch.**

See Specification for battery type information. The battery is marked with the crossed out wheelee bin symbol, which may include lettering to indicate cadmium (Cd), lead (Pb), or mercury (Hg).

For more information see: [www.recyclethis.info](http://www.recyclethis.info)

### **Explanation of symbols:** (Not all may apply)



Fault Indication



Shock Risk - isolate before attempting access



Mains Present



Certification Level



Protective Earth



Do not dispose of in unsorted waste

Specifications subject to change without notice

*The packaging supplied with this product may be recycled.  
Please dispose of packaging accordingly.*